Dovient

Monthly

# Glycol chiller monthly check

Brewery equipment maintenance (glycol chiller, brewhouse)

Site _____ Asset or area _____ Inspected by _____ Date _____

| Item | Pass | Fail | N/A | Notes |
|---|---|---|---|---|
| **Glycol** | | | | |
| Reservoir level at the full mark | | | | |
| Glycol concentration within your target | | | | |
| Supply temperature holding at set point | | | | |
| No leaks at fittings, valves or tank jackets | | | | |
| **Chiller** | | | | |
| Condenser coils clean | | | | |
| Compressor runs with no unusual noise | | | | |
| Fans spin freely and blades not damaged | | | | |
| No ice buildup on lines or evaporator | | | | |
| **Pumps and lines** | | | | |
| Pump seals dry, no leaks | | | | |
| Strainer clean | | | | |
| Line insulation intact, no condensation | | | | |
| Tank solenoid valves open and close on call | | | | |

Signature: _____ Run this checklist on a phone with Dovient Lite: dovient.com/lite