UST walkthrough inspection

EPA UST monthly walkthrough inspection checklist

Site _____ Asset or area _____ Inspected by _____ Date _____

Item	Pass	Fail	N/A	Notes
Spill buckets, every 30 days				
Spill bucket not cracked or damaged				
Spill bucket empty, no liquid or debris				
Fill pipe clear of obstructions				
Fill cap on and secure				
Double-walled bucket interstice shows no leak				
Release detection, every 30 days				
Tank gauge or monitor on and working				
No alarms or unusual conditions on the console				
Release detection records reviewed and current				
Containment sumps, yearly				
Sump not cracked or damaged				
No liquid, debris or product in the sump				
No sign of a release to the environment				
Double-walled sump interstice shows no leak				
Handheld equipment, yearly				
Tank gauge stick readable and not worn				
Groundwater bailer working				

Signature: _____ Run this checklist on a phone with Dovient Lite: dovient.com/lite