Dovient

Monthly, and before each survey window

Assisted living life-safety readiness walk

Assisted living state survey & life-safety readiness checklist

Site _____ Asset or area _____ Inspected by _____ Date _____

Item	Pass	Fail	N/A	Notes
Fire protection				
Fire alarm inspection report current				
Sprinkler inspection report current				
Extinguishers checked this month, tags current				
Kitchen hood system serviced, tag current				
Fire drills done and documented this quarter				
Exits and doors				
Exits and corridors clear of storage				
Exit signs lit				
Emergency lights tested this month				
Fire and smoke doors close and latch				
Delayed-egress and locked doors work as approved				
Building systems				
Generator weekly and monthly tests logged				
Hot water at resident taps within state range				
Call system works in rooms and bathrooms				
HVAC working, rooms at a comfortable temperature				
Resident areas				
Grab bars secure in bathrooms				
Floors even, no trip hazards				
Furniture and beds in good repair				
Chemicals and sharps locked away				

Signature: _____ Run this checklist on a phone with Dovient Lite: dovient.com/lite