Fire extinguisher monthly inspection

Fire extinguisher & fire equipment monthly inspection checklist

Site _____ Asset or area _____ Inspected by _____ Date _____

Item	Pass	Fail	N/A	Notes
Location and access				
In its assigned location				
Nothing blocking access or view				
Location sign or marking visible				
Mounted at the right height, hanger secure				
Condition				
Pressure gauge needle in the green				
Full when lifted (no obvious weight loss)				
Safety pin in place and tamper seal intact				
No dents, corrosion, leaks or other damage				
Hose and nozzle not cracked or clogged				
Operating instructions legible and facing out				
Records				
Annual service tag present and current				
Monthly inspection initialed and dated				

Signature: _____ Run this checklist on a phone with Dovient Lite: dovient.com/lite